



OPEN HOLE INSPECTION REPORT

Laramie County Planning and Development Office
310 W 19th St, Room 400
Cheyenne, WY 82001

Phone: 307-633-4303
Fax: 307-633-4519
planning@laramiecounty.com

Location: Subdivision:		Lot:	Block:
Division:	Section:	Township:	Range:
Address:			

IN ACCORDANCE WITH IRC R401.4.1, OR IBC CHAPTER 18, THE SOIL CONDITIONS OF THE ABOVE REFERENCED SITE WERE DETERMINED BY ME ON _____(DATE) AND THE FOLLOWING CONDITIONS WERE NOTED:

1. SOIL BEARING PRESSURE OF _____ PSF MAXIMUM
 - a. BASED ON SOILS REPORT NO.: _____
 - OR
 - b. BASED ON RATIONAL EVALUATION:
2. THE FOOTING/FOUNDATION IS TO BE PLACED ON UNDISTURBED NATURAL SOIL ___YES ___ NO
IF NOT, ATTACH COMPACTION REPORT AND SOILS REPORT
3. UNUSUAL MOISTURE PRESENT? ___ YES ___ NO
4. EXPANSIVE SOILS WERE PRESENT? ___ YES ___ NO
5. THE SOIL CLASSIFICATION (TYPE) IS (check one):
 - a. Clay, sandy clay, silty clay, clayey silt, silt and sandy silt (CL, ML, MH and CH).
Load-bearing pressure (PSF) 1,500 _____ .
 - b. Sand, silty sand, clayey sand, silty gravel and clayey gravel (SW, SP, SM, SC, GM, AND GC).
Load-bearing pressure (PSF) 2,000 _____ .
 - c. Sandy gravel and/or gravel (GW and GP). Load-bearing pressure (PSF) 3,000 _____ .
 - d. Sedimentary and foliated rock. Load-bearing pressure (PSF) 4,000 _____ .
 - e. Crystalline bedrock. Load-bearing pressure (PSF) 12,000 _____ .

THE TYPE OF FOOTING/FOUNDATION REQUIRED FOR THIS SITE SHALL BE: _____

SIGNED: _____ WYO. REG. NO.: _____
PRINT NAME: (Required) _____ DATE: _____

This report cannot be accepted if the name is not legible printed.

THIS DOCUMENT MUST BE COMPLETED AND RETURNED TO THE LARAMIE COUNTY PLANNING AND DEVELOPMENT OFFICE **PRIOR TO PLACING ANY CONCRETE**